




HVAC 101:
Residential
Typical system components & cleaning techniques



Copyright © 2016 NADCA. All Rights Reserved.
No part of this publication may be reproduced or distributed by any means, electronic or mechanical, including photocopy, recording, or any other information storage and retrieval system, without prior written consent from the publisher.

Presenter





Robert Rizen

Robert Rizen is the General Manager of Iaq & Restoration services. He has been involved with air conveyance cleaning since 1989 as well as full service restoration operations.

*Email: Robert.rizen@gmail.com
Cell: 314-518-1681
<https://www.linkedin.com/in/robertrizen>*

Disclaimer



This presentation is not intended to be a comprehensive program covering all aspects of this topic. All technicians are encouraged to read and follow all applicable standards, codes and regulations related to this topic.

- ✓ It is the responsibility of each individual contractor to follow local building codes and licensing requirements and to work safely in accordance with OSHA guidelines.
- ✓ It is the contractor's responsibility to take proper precautions on each project to prevent cross contamination. Always take the health and safety of the building occupants into consideration before you conduct any cleaning procedures.
- ✓ All of the following tips are only general tips. They do not cover every situation and it is your responsibility to adapt these tips to the individual system you are working on.
- ✓ The Instructor is not responsible in any way for the work you perform after viewing this slide show. You are responsible for your own work.
- ✓ The views and opinions following are the instructors opinions and not necessarily the official position of the National Air Duct Cleaners Association.


**TECHNICAL
NADCA
CONFERENCE**

Residential
HVAC 101

Supplemental Materials

This session covers key points but not every detail.
The tips & techniques presented are for cleaning & restoration procedures.
For a full understanding of this topic, attendees are encouraged to review additional materials including:

NADCA Standard ACR



**TECHNICAL
NADCA
CONFERENCE**

What We'll
Learn

- Types of HVAC Systems
- Typical Components
- Tips for Cleaning These Systems
- Cleaning Requirements

**TECHNICAL
NADCA
CONFERENCE**

Residential
HVAC 101


Section 1
Types of HVAC systems

- Up flow System
- Down flow System
- Ductless
- Geo Thermal
- Multi Zone



Residential HVAC 101


System Types & Locations





Residential HVAC 101


Up Flow System





Residential HVAC 101

Down Flow System





Residential HVAC 101

Ductless Mini System





Residential HVAC 101


Geo Thermal System







Residential HVAC 101

Multi Zone – Multi Damper



Types of Systems





Residential HVAC 101

Section 2
Typical Components of Residential Systems

- Ductwork
- Registers
- Furnace Fan
- Evaporator Coils & Drain
- Humidifier
- Washable Air Filter



Residential HVAC 101


Typical Components:
Supply & Return Air Duct Work



**TECHNICAL
NADCA
CONFERENCE**

Residential
HVAC 101


**Typical Components:
Registers & Vent Covers**



**TECHNICAL
NADCA
CONFERENCE**

Residential
HVAC 101

**Typical Components:
Furnace Fan**



**TECHNICAL
NADCA
CONFERENCE**

Residential
HVAC 101


**Typical Components:
Evaporator Coil & Drain pan**



TECHNICAL
NADCA
CONFERENCE

Residential
HVAC 101

Typical Components:
Humidifier



TECHNICAL
NADCA
CONFERENCE

Residential
HVAC 101


Typical Components:
Washable Media Air Filters



TECHNICAL
NADCA
CONFERENCE

Residential
HVAC 101

Typical Components:
Real Life Install



Typical Components

Q&A
You have Questions
We have Answers

TECHNICAL
NADCA
 CONFERENCE

Residential HVAC 101

Section 3
Cleaning Methods

NADCA does not endorse or recommend any single method of cleaning or type of equipment.

NADCA recommends the use of source removal methods and equipment designed to clean HVAC systems to the cleanliness levels specified in NADCA Standard ACR.

Each different cleaning method has its advantages and disadvantages

TECHNICAL
NADCA
 CONFERENCE

Residential HVAC 101

Section 3
Cleaning Methods: Vacuum Collection

Good negative air (suction) is a must for capturing the particulate.




Residential HVAC 101

Section 3 Cleaning Methods: Vacuum Collection

A vacuum collection device alone will not get an HVAC system clean.


Methods and tools designed to agitate debris adhered to surfaces along with use of vacuum collection device(s), is required.





Residential HVAC 101


Section 3 Cleaning Methods: Brushing





Residential HVAC 101

Section 3 Cleaning Methods: Air Washing






Residential HVAC 101

Section 3 Cleaning Methods: Air Washing


Whips, Rods, Blast Nozzles





Residential HVAC 101

Section 3 Cleaning Methods: Contact Vacuuming





Residential HVAC 101

Section 3 Cleaning Methods: Hand Washing


This procedure is just what its name implies- washing components by hand.

Involves hand tools such as brushes, sponges or damp cloths to wipe clean a designated area.



Liquids cannot be applied to porous components such as fibrous glass. Make sure that no chemical residues are left in the system during hand washing.

Cleaning Methods



Q&A
you have Questions
We have Answers

TECHNICAL NADCA CONFERENCE

Residential HVAC 101

Section 3
Component Cleaning - Fans



Fan Compartment
Fan Housing
Fan Blades or Vanes
Motor/ Drive Assemblies

TECHNICAL NADCA CONFERENCE

Residential HVAC 101

Section 3
Component Cleaning - Fans




TECHNICAL NADCA CONFERENCE


Residential HVAC 101

Section 3
Component Cleaning – Evaporator Coils


Dirty Coils



Clean Coils!



Vacuum with brush
Blow out with air
Aerosol cleaner
Pump sprayer with chemical



TECHNICAL NADCA CONFERENCE

Residential HVAC 101

Section 3
Component Cleaning – Evaporator Coils

- Containment – separate coil from furnace with sheet metal or poly
- Capture water during cleaning with a wet vac, vacuum out the drain pan as needed
- Always verify drain line from the pan is actually operational before wet cleaning!
- Go slowly- the pan is small and only holds a small amount its easy to over flow.

TECHNICAL NADCA CONFERENCE

Residential HVAC 101

Section 3
Component Cleaning – Drain Lines

The condensate drain pan and line should be flushed
Verify operation before cleaning
Blow out with compressed air first to remove large buildup





Usually a drain pan and line have the highest amounts of contamination when compared to all other system components.

TECHNICAL
NADCA
CONFERENCE

Residential
HVAC 101

Section 3
Component Cleaning – Duct System Tips



It's faster to cut an access opening and vacuum large debris out of the ducts instead of trying to use air to push it towards the collection unit.

TECHNICAL
NADCA
CONFERENCE

Residential
HVAC 101

Section 3
Component Cleaning – Duct System Tips


Here's a Tip...

- Standardize your access holes – Only stock 2 sizes of premade sheet metal patches on your truck
- Try to minimize your trips to the truck – steps cost money, bring in your tools from the beginning
- Establish negative air before you remove vent covers- this helps to minimize mess inside the home when covers are removed

TECHNICAL
NADCA
CONFERENCE

Residential
HVAC 101

**Component Cleaning:
Ductless Mini Split**




Same components of a standard furnace, just compact. Contains a fan, filter, evaporator coil, and drain pan.

TECHNICAL NADCA CONFERENCE

Residential HVAC 101

Component Cleaning: Ductless Mini Split



Remove covers, vacuum fan and coils.

Compressed air can be used to blow items out.


Purchase or create a containment to capture the water overflow to wet clean the coils.

Here's a Tip...

TECHNICAL NADCA CONFERENCE

Residential HVAC 101

Component Cleaning: Geothermal Air Handler



Mysterious looking?

TECHNICAL NADCA CONFERENCE

Residential HVAC 101

Component Cleaning: Geothermal Air Handler



Same components as normal furnaces, fan, coils, drain pan.

Be aware of coil placement, usually on return air side of the system.

Tightly spaced coils, don't tolerate aggressive cleaning agents.

TECHNICAL NADCA CONFERENCE

Residential HVAC 101

**Component Cleaning:
Humidifiers**



TECHNICAL NADCA CONFERENCE

Residential HVAC 101

**Component Cleaning:
Humidifiers**

- Disassemble and wash components
- Pad can be replaced and sometimes washed
- Verify that drain is working
- Havn microbial issues often times start with the humidifier and evaporator coils.

TECHNICAL NADCA CONFERENCE

Residential HVAC 101

**Component Cleaning:
Washable Media Air Filters**



Wash with mild detergent, coil cleaner or degreaser

TECHNICAL
NADCA
CONFERENCE

Residential HVAC 101

ACR
2015

Section 4:
Cleaning Requirements & Standards

HVAC System Cleaning Requirements

- Visibly Clean
- Source Removal
- Negative Duct Pressurization
- Service Openings
- Containment


TECHNICAL
NADCA
CONFERENCE

Residential HVAC 101

Section 4:
Cleaning Requirements & Standards

Cleaning Methods

- Vacuum Collection
- Brushing
- Air Washing
- Hand or Contact Vacuuming
- Hand Washing
- Power Washing



TECHNICAL
NADCA
CONFERENCE

Residential HVAC 101

Section 4:
Cleaning Requirements & Standards

Visibly Clean Standard

Key Terms

Visibly Clean:
An interior surface is considered visibly clean when it is free from "non-adhered" substances and debris.

Definition: What does non-adhered mean?

Any material not intended or designed to be present in an HVAC system, and which can be removed by contact vacuuming.




TECHNICAL NADCA CONFERENCE

Residential HVAC 101

**Section 4:
Cleaning Requirements & Standards**



Source Removal

Key Terms

Source Removal
The mechanical cleaning of system components to remove dirt and debris.

Requires two key elements to be effective:

1. **Agitation** of dust and debris within the HVAC system.
2. **Extraction** of contaminants from the HVAC system

TECHNICAL NADCA CONFERENCE

Residential HVAC 101


**Section 4:
Cleaning Requirements & Standards**

Negative Duct Pressurization

Key Terms

Negative Pressure
Used to prevent debris from entering the occupied space or leaving the contained area.

Prior to and throughout the duration of the cleaning process, the HVAC system and associated air duct *shall* be kept at an appropriate negative pressure differential relative to the indoor non-work area.



TECHNICAL NADCA CONFERENCE

Residential HVAC 101

**Section 4:
Cleaning Requirements & Standards**

Effective negative pressure containment requires:

- Physical barrier around work area
- Sealing off HVAC return air grills
- Continuously pulling air through a HEPA filtration device to reduce airborne particles.
- Exhausting more cubic feet per minute of clean, HEPA-filtered air out of the space than is supplied into it.

TECHNICAL NADCA CONFERENCE

Residential HVAC 101

**Section 4:
Cleaning Requirements & Standards**

Participant Poll Question:

Has anyone experienced an HVAC System cleaning job where negative pressurization was not maintained properly?

If so, what was the result?

TECHNICAL NADCA CONFERENCE

Residential HVAC 101



**Section 4:
Cleaning Requirements & Standards**

Service Openings

Minimum Requirements for Service Openings

Service openings shall:

- not** degrade the structural, thermal, or functional integrity of the system;
- not** hinder, restrict, or alter the airflow within the air duct;
- not** be made in flexible ductwork;
- be** created in a manner that allows for proper closure;
- comply** with applicable UL, SMACNA and NFPA standards, as well as local, regional, state and federal codes.

TECHNICAL NADCA CONFERENCE

Residential HVAC 101

**Section 4:
Cleaning Requirements & Standards**

Service Openings


Service Panels

- Shall be of an equivalent gauge or heavier
- Shall be mechanically fastened (screwed or riveted) at minimum every 4" on center.
- Shall overlap the ductwork surfaces by a minimum of 1" on all sides.
- Recommended to be sealed with gaskets, duct sealants, mastic or tape.




TECHNICAL
NADCA
CONFERENCE

Residential
HVAC 101




**Section 4:
Cleaning Requirements & Standards**

Evaporator Coils


All portions of each coil assembly must be cleaned.

- Both upstream and downstream sides of each coil section *shall* be accessed for cleaning.
- When both sides of a coil are not accessible for cleaning then removal and/or replacement *may* be required.
- Visual inspection of the coil and drain pan will determine whether Type 1 or Type 2 cleaning is required.



TECHNICAL
NADCA
CONFERENCE

Residential
HVAC 101



**Section 4:
Cleaning Requirements & Standards**

Evaporator Coils

The substances impacted on the evaporator coil help determine the initial cleaning protocol. Evaporator coil cleaning is broken into two (2) categories known as **Types**. Evaporator coil reconditioning will utilize **Type-1** or **Type-2** cleaning methods.

```


graph TD
    A[Evaporator Coils] --> B[Type 1 (Dry Cleaning)]
    A --> C[Type 2 (Wet Cleaning)]
  
```

TECHNICAL
NADCA
CONFERENCE

Residential
HVAC 101

**Section 4:
Cleaning Requirements & Standards**

Pop Quiz Does this coil require Type 1 or Type 2 cleaning?



**TECHNICAL
NADCA
CONFERENCE**

Residential
HVAC 101

**Section 4:
Cleaning Requirements & Standards**

Answer:

Perform a Type 1 cleaning.


After performing Type 1 cleaning determine whether you need to proceed to Type 2 cleaning.

**TECHNICAL
NADCA
CONFERENCE**

Residential
HVAC 101

**Section 4:
Cleaning Requirements & Standards**

Participant Poll Question:
Recommend Cleaning or Replacement?



**TECHNICAL
NADCA
CONFERENCE**

Residential
HVAC 101

**Section 4:
Cleaning Requirements & Standards**

Containment



Be prepared to cover everything in your work area if needed.

TECHNICAL NADCA CONFERENCE

**Section 4:
Cleaning Requirements & Standards**

Residential HVAC 101

Containment




Simple critical barriers

TECHNICAL NADCA CONFERENCE

**Section 4:
Cleaning Requirements & Standards**

Residential HVAC 101

Containment



Coils covered by cardboard, keeps debris from damaging coils

TECHNICAL NADCA CONFERENCE

**Section 4:
Cleaning Requirements & Standards**

Residential HVAC 101

Containment



Replace filter with cardboard, sheet metal etc. to section furnace from duct system

Residential HVAC 101

Q&A
you have Questions
We have Answers

Residential HVAC 101

Conclusion

- Residential HVAC Types
- Common Components
- Cleaning Procedures
- Standards

Residential HVAC 101

Presenter Contact Information

- Robert Rizen
- Robert.rizen@gmail.com
- 314-518-1681